

TABLE 62 - SINGLE POINT TERMINAL BLOCK HIGH AIR FLOW FANS (PIN 52 = G) (BX) (CONT'D)

ITEM	DESCRIPTION	MODEL	VOLTAGE (PIN 11 & 12)	PART NUMBER	FIGURE
6	Circuit Breaker, 600V, 250A	QTC3055T, QTC3060T	40, 46	024-35974-000	35
	Circuit Breaker, 600V, 400A	QTC3070T	40	024-35976-000	
	Circuit Breaker, 600V, 250A		46	024-35974-000	
	Circuit Breaker	QTC3075T, QTC3080T	40	-	
	Circuit Breaker, 600V, 250A		46	024-35974-000	
	Circuit Breaker, 600V, 400A	QTC3085T	40	024-35976-000	
	Circuit Breaker, 600V, 250A		46	024-35974-000	
	Circuit Breaker, 600V, 400A	QTC3090T	40, 46	024-35976-000	
	Circuit Breaker	QTC3095T, QTC3100T	40	-	
	Circuit Breaker, 600V, 400A		46	024-35976-000	
	Circuit Breaker	QTC3110T	40	-	
	Circuit Breaker, 600V, 400A		46	024-37079-000	
	Circuit Breaker, 600V, 600A	QTC3120T	40	024-37004-000	
	Circuit Breaker, 600V, 400A		46	024-35976-000	
	Circuit Breaker, 600V, 600A	QTC3125T, QTC3130T	40	025-37004-000	
	Circuit Breaker, 600V, 400A		46	024-37079-000	
	Circuit Breaker, 600V, 600A	QTC3140T, QTC3160T, QTC3170T	40	025-37006-000	
	Circuit Breaker, 600V, 600A		46	025-37004-000	
Circuit Breaker, 600V, 600A	QTC3150T	40	025-37006-000		
Circuit Breaker, 600V, 400A		46	024-37079-000		
6A	Operator Mechanism, Circuit Breaker	QTC3055T - QTC3170T	ALL	025-34409-000	
7	Ground Lug, Copper	QTC3075T, QTC3080T	46	025-34088-000	35
		QTC3125T, QTC3130T	40, 46	025-34455-000 025-29194-000	
8	Ground Lug, Copper	QTC3055T	40	025-34455-000 025-29194-000	35
			46	025-34088-000	
		QTC3060T, QTC3085T, QTC3090T	40,46	025-34455-000 025-29194-000	
		QTC3070T	40	025-34455-000 025-29194-000	
		QTC3095T	46	025-34088-000	
		QTC3110T, QTC3140T, QTC3150T	46	025-34455-000 025-29194-000	
		QTC3120T, QTC3125T, QTC3130T	40, 46	025-34088-000	
QTC3140T, QTC3150T, QTC3160T, QTC3170T	40	025-34088-000			

NOTE:

* Items are NOT represented.

** Make a visual inspection of the fuses and contactors in order to select the correct replacement part, refer to Table 65 on page 113.